



ift, P.O.Box 10 04 51, 83004 Rosenheim, GERMANY

Door & Window Hardware Co.
12F1, No. 666, Sec. 2, Wu Chuan West Road

40869 Taichung, Taiwan
ROC

Your ref.
Your letter dated
Our ref. spa
Phone +49 (8031) 261-1674
E-Mail spreitzer@ift-rosenheim.de
Rosenheim 29 04 2011

Dear Mr. Chang,

we hereby confirm that the lock of the type LK 500 in accordance with
DIN 18251:2002 Part 1 have reached the following partial results:

- durability latch 200.000 cycles Class 3
- durability bolt 50.000 cycles Class 3
- corrosion test according to DIN EN 1670 Class 3

On the basis to the almost identical structural features, the locks can be of type
LK 500 SQ, LK 500 X and LK 500 R are compared with the tested lock LK 500.

Best regards
ift Rosenheim

i. A. Alexander Spreitzer
Produktingenieur
Bauteile